



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY PALI

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem)/2026-2027/

296

Dated : 29/5/2026

To,

Assistant Engineer
PHED. Sub Dn.
Sojat City

District: Pali
Block: Sojat

Reference : Your Letter No.

244

Dated: 27/05/2026

Name of Sample Taker: -

Date of Receipt : 27/05/2026

Ref ID: 24

Source	Treated Water	TW			
Source Location	RO Plant, In Gokul School, Chandawal	TW, Un treated water, In Gokul School			
Habitation	Chandawal Nagar	Chandawal			
Village/Town	Chandawal	Chandawal			
Gram Panchayat	Chandawal	Chandawal			
Date of Collection	27/05/2026	27/05/2026			
Date of Examination	29/05/2026	29/05/2026			
Lab. Sample No.	396	397			
Note :- All results Except pH are in mg/L					
1 pH	6.6	7.9			
2 Turbidity(NTU)	Clear	Clear			
3 Colour	None	None			
4 Odour	ND	ND			
5 Temperature (°C)	25	25			
6 Total Alkalinity (as CaCO ₃)	90	350			
7 Total Hardness (as CaCO ₃)	50	250			
8 Calcium Hardness (as CaCO ₃)	30	140			
9 Magnesium Hardness (as CaCO ₃)	20	110			
10 Chloride (as Cl ⁻)	40	240			
11 Sulphate (as SO ₄ ⁻²)	-	-			
12 Nitrite (as NO ₂ ⁻)	-	-			
13 Nitrates (as NO ₃ ⁻)	2	9			
14 Fluoride (as F ⁻)	0.34	0.62			
15 Total Dissolved Solids	178	1130			
16 Residual Chlorine	-	-			

Senior Chemist
PHED Lab Pali

Dated:

No. Lab/Tech(Chem)/2026-2027/

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2 The Executive Engineer, PHED Division, Pali/Sojat/Falna
- 3

Senior Chemist

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 475

Dated: 17.7.26

It is certified that an inspection team headed by Kuleep Singh

(Name of Officers with designation) from Junior Engineer PHED Surat

(Name of Department/ Office) inspected the GOKUL SCHOOL CHANDAWAL
MURDAWAR ROAD CHANDAWAL(Name & Address of the school) on NAGAR (date of inspection) and found that the
GOKUL SCHOOL CHANDAWAL (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of one year (1).

✱
OB

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

(Jishu)
सहायक अभियन्ता
जन. स्वा. अभि. विभाग
उपखण्ड सोजत नगर
कोड सं.- ०६

To

GOKUL SCHOOL CHANDAWAL

MURDAWAR ROAD,
CHANDAWAL NAGAR.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.